



DISTRICT LEVEL WATER ANALYSIS LABORATORY

Uttar Pradesh Jal Nigam (Gramin)

**Add.- Office Of Executive Engineer, Division Office Dondaghat Talabpura
Lalitpur (UP) 284403**

Phone No. :- 05176-276732

Email Add.:- pmialltp@gmail.com

No. 3806 / M-14 / 60

Date:- 29/08/2024

ANNEXURE -C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certificate that an inspection team by **Quality Manager, Miss PRIYANKA PAL** From District Level Water Analysis Laboratory, U.P. Jal Nigam (Gramin) Lalitpur, Inspected the **"SUNRISE VIDHYAPEETH"** on 23-08-2024 and on the basic of water test Report (Attached) bearing No. **LTP/PS/24/12** Dated 24-08-2024 Of District Level Water Analysis Laboratory Lalitpur Certified that the **"SUNRISE VIDHYAPEETH"** has safe drinking water facilities for the hygienic sanitation condition in the school building & the campus as per the norm prescription by the Central/State/U.T. Govt.

This Certificate is valid 6 Month

To,
SUNRISE VIDHYAPEETH
Tekri Talbehath (Talbehath Andar)
District- Lalitpur 284403


Lab-In-Charge (Lab)
District Level Water Analysis Laboratory
UP Jal Nigam (Gramin), Lalitpur
सहायक अभियन्ता
खण्ड कार्यालय
उत्तर प्रदेश जल निगम (ग्रामीण)
ललितपुर



District Level Water Analysis Laboratory of

Office Of Executive Engineer, Khand Karyalay, Dhondaghat Road Talabpura (Lalitpur), 284403

TEST REPORT

Report No.: C/LTP/PS/24/12

Date: 09/08/24

No. of Pages: / 12

Customer Details

Office Name and Address Executive Engineer, U.P.J.N(Rural), Lalitpur-284403

Ref. Letter No. & Date 08/2024

Date: 07/08/24

Basic Details of Sample

District	Lalitpur	Block	Talbehat
Gram Panchayat	Khandi	Village	Tetki (Talbehat)
Habitation		Location	Sunrise Vidhyapeeth school
Water Source	RO water	Sample Code	LTP/PS/24/12
Quantity of Sample	1000 ml	Sampling date	23/08/24
Sample Received Date	23/08/24	S. collected by	Rajkumar Yadav
Sampling Method Used	IS 17614 (Part 3):2022	Sample Depositor	Rajkumar Yadav
Analysis Start Date	23/08/24	Analysis Completion date	24/08/24

S. No.	Analysed Parameters(Unit Of Measurement)	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
3	pH @25°C	6.98	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
4	Turbidity (NTU)	0.241	1	5	IS 3025 (Part 10):2023 (Nephelometric method)
5	Total Dissolved Solids, mg/l	128	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
6	Chloride (as Cl), mg/l	39	250	1000	IS 3025 (Part 32): 2019 Argentometric method
7	Total Alkalinity, (as CaCO ₃) mg/l	8	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
8	Total Hardness, (as CaCO ₃)	80	200	600	IS 3025 (Part 21): 2019 (EDTA method)
9	Calcium (as Ca), mg/l	—	75	200	IS 3025 (Part 40): 2019 EDTA Titrimetric method
10	Magnesium (as Mg), mg/l	—	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
11	Fluoride (as F), mg/l	0.035	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion-Selective Electrode Method) : 2023

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

Note: 1. This certificate refers only to the particular sample(s) submitted for testing.

2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.

3. The analysis/test results reported in this certificate are valid at the time of and under the stated conditions of measurements.

4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.

(Reviewed by)

29/08/24

(Authorized Signatory)
(Priyanka Patil)
Quality Manager
U.P.J.N, LALITPUR

Laboratory Contact detail:

Email: lablalitpur2023@gmail.com

Mobile No.: 7239091044

*****END OF THE TEST REPORT*****